






STEWART OBSERVATORY KITT PEAK 90" TELESCOPE		
Title ABB DOME DRIVES - BLOCK DIAGRAM		
Size A	Document Number 21454	Rev A
Date:	Wednesday, April 05, 2017	Sheet 1 of 4

KEY SWITCH and PUSH BUTTONS



RELAY BLOCK





480 VAC
3-PHASE
w/GND

REMOTE
SIGNALS

TO
LOCAL
MOTOR

TO
REMOTE
MOTOR

Title		
ABB DOME DRIVE ENCLOSURE		
Size	Document Number	Rev
B	<Doc>	A
Date:	Wednesday, April 05, 2017	Sheet 1 of 1



KEY SWITCH



800FP-KM21	KEY SWITCH ASSEMBLY
800F-11WE147	LEGEND PLATE LOCAL/REMOTE
800F-X01	CONTACT BLOCK N.C.

PUSH BUTTON x 2



800FP-F3PX10	PUSH BUTTON GREEN
800F-X10	CONTACT BLOCK N.O.

800F-ALP

PLASTIC LATCH




Title <Title>		
Size B	Document Number <Doc>	Rev A
Date:	Wednesday, April 05, 2017	Sheet 1 of 1



- 800FP-KM21 KEY SWITCH ASSEMBLY
- 800F-11WE147 LEGEND PLATE LOCAL/REMOTE
- 800F-ALP PLASTIC LATCH
- 800F-X01 CONTACT BLOCK N.C.
- 800F-X10 CONTACT BLOCK N.O.

Title		
<Title>		
Size	Document Number	Rev
B	<Doc>	A
Date:	Wednesday, April 05, 2017	Sheet 1 of 1
Title		
<Title>		
Size	Document Number	Rev
B	<Doc>	<Rev Code>
Date:	Wednesday, April 05, 2017	Sheet 1 of 1

DOME LEFT and RIGHT SIGNALS FROM the SECOND FLOOR FOR REMOTE DOME MOTION



REMOTE / LOCAL SWITCH

- SELECTOR SWITCH 800FP-SM22
- LOCAL/REMOTE LEGEND PLATE 800F-11WE147
- CONTACT BLOCK N.C 800F-PQ21

RIGHT and LEFT PUSH BUTTONS

- PUSH BUTTON GREEN 800FP-F3PX10
- CONTACT BLOCK N.O. 800f-x10

800F-ALP
PLASTIC LATCH






ABB ASC355-03U-12A5-4

X1A	
1	
2	
3	
4	
5	
6	
7	
8	
9	+24V
10	GND
11	DCOM
12	D11
13	D12
14	
15	
16	
X1B	
17	
18	
19	
20	
21	
22	
X1C	
STO	
1	
2	
3	
4	






Title		
90" ABB DOME DRIVE - SIGNAL WIRING		
Size B	Document Number <Doc>	Rev A
Date:	Saturday, April 15, 2017	Sheet 1 of 1



CONTROL ROOM
ON/OFF SWITCH
and EMERGENCY
STOP BUTTON







480VAC 3-PHASE
DISCONNECT



STEWART OBSERVATORY KITTE PEAK 90" TELESCOPE		
Title ABB DOME DRIVE - AC WIRING		
Size B	Document Number 21454	Rev A
Date: Wednesday, April 05, 2017	Sheet 2	of 4

SIGNALS FROM FROM 2ND FLOOR RELAYS

120 VAC HOT
 120 VAC MOVE LEFT
 120 VAC MOVE RIGHT
 120 VAC NEUTRAL



vio +24V
 blk MOVE LEFT
 wht MOVE RIGHT

- X1A
- 1
- 2
- 3
- 4
- 5
- 6
- 7
- 8
- 9
- 10
- 11
- 12
- 13
- 14
- 15
- 16
- X1B
- 17
- 18
- 19
- 20
- 21
- 22
- X1C
- STO
- 1
- 2
- 3
- 4




ABB ASC355-03U-12A5-4

STEWART OBSERVATORY KITT PEAK 90" TELESCOPE		
Title ASC355 DOME DRIVES SIGNAL WIRING		
Size B	Document Number 21454	Rev A
Date: Wednesday, April 05, 2017	Sheet 3	of 4